

Horry Electric Cooperative, Inc.

A Touchstone Energy® Cooperative 

All meter bases connected to the Horry Electric Cooperative system must meet certain specifications in order for power to be connected.

Approved Manufacturers and Models - 1 phase gang sockets

Effective February 12, 2009

Please visit horryelectric.com for the most up-to-date list

	Culter Hammer/Eaton	Milbank	Siemens/L&G	Durham/Square D
2 position, with lay-in type lugs, 200amps/position, 200 amps overall ampacity	UT2R2332TCH	U1252-X-K1-CAPL	UA2717-YJCA	T-2R2332U
3 position, with lay-in type lugs, 200 amps/position, 270 amps overall ampacity	UT3R2332TCH	U1253-X-K1-CAPL	UA3717-YJCA	T-3R2332U
4 position, with lay-in type lugs, 200 amps/position, 360 amps overall ampacity	UT4R2352TCH	U1254-X-K1-CAPL	UA 4719-YJCA	T-4R2352U
5 position, with lay-in type lugs, 200 amps/position, 450 amps overall ampacity	UT5R2392TTCH	U1255-X-K1-CAPL	UA5719-KJCA	T-5R2392U
6 position, with lay-in type lugs, 200 amps/position, 528 amps overall ampacity	UT6R2392TTCH	U1256-X-K1-CAPL	UA6719-KJCA	T-6R2392U

notes

U in front of Durham part # puts a UL sticker on the base

red text are bases we are currently using