

# Horry Electric Cooperative, Inc.

A Touchstone Energy® Cooperative 

**All meter bases connected to the Horry Electric Cooperative system must meet certain specifications in order for power to be connected.**

## Approved Manufacturers and Models - 1 phase meter sockets

Effective August 2015

Please visit [horryelectric.com](http://horryelectric.com) for the most up-to-date list

	Culter Hammer/Eaton	Milbank	Siemens/L&G	Durham/Square D
125 amp, with lay-in type lugs	UTRS111BCH UTRS101BCH	U7487-RL-QG-CAPL	UAT 111-0JCA	N/A
200 amp, with lay-in type lugs	U92197CCCPLCH	U1980	UAS 917-XJCA	N/A
200 amp, with lay-in type lugs on line side, 3/8" studs on load side	N/A	N/A	UAS 917-OG	N/A
400 amp Bolt-in, type K-4, with 1/2" studs on line and load side	CH8416K4	S4664-X-8416	9809-8416	N/A
320 amp, with lever bypass, 3/8" studs on line and load side	UTH4300UCH UTH4300TCH	U-1129-RXL U5740-X-K3L-K2L-CAPL	4760U4-82	T-H 4300U

### notes

U in front of Durham part # puts a UL sticker on the base

red text are bases we are currently using